

PWS Name	Class	Contaminant Group	Chemical Name	Collected Date	Result	UOM	Reporting Limit	Location Name	Raw or Finished	Maximum Contaminant Level (MCL)	Lab Reported Detection Limit	Required Detection Limit
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	10/12/2021	3.24	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6090 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	10/28/2021	4.48	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.5940 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	12/02/2021	2.76	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6190 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	12/06/2021	2.92	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.6040 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/27/2022	ND	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6480 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/27/2022	ND	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.6240 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	04/29/2022	3.85	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.7060 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	04/29/2022	3.03	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6170 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	09/14/2022	4.48	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.6340 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	09/14/2022	2.21	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6040 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	11/02/2022	3.85	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.6620 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	11/02/2022	2.39	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6050 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/10/2023	3.88	NG/L	2 NG/L	RAW: SALMON BROOK GP WELL NO. 2	R	20	0.6000 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/10/2023	2.37	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.1	F	20	0.6280 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/10/2023	2.51	NG/L	2 NG/L	RAW: SALMON BROOK GP WELL NO. 1	R	20	0.6160 NG/L	2.0000
DUNSTABLE WATER DEPARTMENT	COM	PFAS	PFAS6	01/10/2023	4.11	NG/L	2 NG/L	TREATED: SALMON BROOK GP WELL NO.2	F	20	0.6350 NG/L	2.0000
GOSS FARM, INC.	NC	PFAS	PFAS6	03/17/2022	ND	NG/L	2 NG/L	WELL #1 FINISHED WATER	F	20	0.6010 NG/L	2.0000
YMCA CAMP MASSAPOAG	NC	PFAS	PFAS6	05/15/2022	4.63	NG/L	1.8000 NG/L	WELL #1 SAMPLING TAP	F	20	0.5950 NG/L	2.0000