

PWS Name	Class	Contaminant Group	Chemical Name	Collected Date	Result	UOM	Reporting Limit	Location Name	Raw or Finished	Maximum Contaminant Level (MCL)	Lab Reported Detection Limit
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	10/15/2021	53.3	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6070 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	11/04/2021	62.6	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.5990 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	12/20/2021	55.1	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6160 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	01/04/2022	47.2	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6040 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	02/01/2022	59.93	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6460 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	03/01/2022	67.4	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6000 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	03/01/2022	490	NG/L	2 NG/L	RAW WATER: WELL #1	R	20	0.6160 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	04/20/2022	57.5	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6130 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	07/27/2022	428	NG/L	9.0100 NG/L	RAW WATER: WELL #1	R	20	3.0100 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	07/27/2022	114	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6070 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	10/18/2022	126	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6540 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	01/16/2023	181	NG/L	2 NG/L	WELL #1 (AFTER TREATMENT & STORAGE)	F	20	0.6030 NG/L
GROTON DUNSTABLE REG. H.S.	NTNC	PFAS	PFAS6	01/24/2023	431	NG/L	2 NG/L	RAW WATER: WELL #1	R	20	0.6090 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/28/2019	2.44	NG/L	1.8200 NG/L	WHITNEY WTF WELL #1 (TREATED)	F		Not Recorded
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/28/2019	4.77	NG/L	1.8900 NG/L	BADDACOOK POND WELL (TREATED)	F		Not Recorded
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/28/2019	ND	NG/L	1.8200 NG/L	WHITNEY WTF WELL #2 (TREATED)	F		Not Recorded
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/12/2021	ND	NG/L	2 NG/L	RAW WATER: WHITNEY POND WELL #2	R	20	0.6230 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/12/2021	2.03	NG/L	2 NG/L	WHITNEY POND TREATMENT FACILITY (BLEND)	F	20	0.6160 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/12/2021	ND	NG/L	2 NG/L	BADDACOOK POND WELL (TREATED)	F	20	0.6090 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	10/12/2021	2.17	NG/L	2 NG/L	RAW WATER: WHITNEY POND WELL #1	R	20	0.6030 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	01/11/2022	ND	NG/L	2 NG/L	BADDACOOK POND WELL (TREATED)	F	20	0.6230 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	01/11/2022	ND	NG/L	2 NG/L	WHITNEY POND TREATMENT FACILITY (BLEND)	F	20	0.6110 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	04/06/2022	ND	NG/L	2 NG/L	BADDACOOK POND WELL (TREATED)	F	20	0.6270 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	04/07/2022	2.15	NG/L	2 NG/L	WHITNEY POND TREATMENT FACILITY (BLEND)	F	20	0.6770 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	07/13/2022	8.53	NG/L	2 NG/L	BADDACOOK POND WELL (TREATED)	F	20	0.6190 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	07/13/2022	2.99	NG/L	2 NG/L	WHITNEY POND TREATMENT FACILITY (BLEND)	F	20	0.6240 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	11/09/2022	2.58	NG/L	2 NG/L	BADDACOOK POND WELL (TREATED)	F	20	0.5990 NG/L
GROTON WATER DEPARTMENT	COM	PFAS	PFAS6	11/09/2022	2.04	NG/L	2 NG/L	WHITNEY POND TREATMENT FACILITY (BLEND)	F	20	0.5970 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	05/23/2022	16.5	NG/L	1.7200 NG/L	WELL #1: WELLHOUSE (MAIN CENTER)	F	20	0.5660 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	05/23/2022	79.4	NG/L	1.7100 NG/L	WELL #2: PUMP ROOM (MAIN DINING HALL)	F	20	0.5640 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	05/23/2022	19.2	NG/L	1.7100 NG/L	WELL #3: PUMP ROOM (ADULT CENTER)	F	20	0.5640 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	05/23/2022	1.78	NG/L	1.7600 NG/L	WELL #4: PUMP ROOM (FAMILY CENTER)	F	20	0.5820 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	06/21/2022	70.4	NG/L	2 NG/L	WELL #2: PUMP ROOM (MAIN DINING HALL)	F	20	0.5990 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	06/21/2022	17.5	NG/L	2 NG/L	WELL #1: WELLHOUSE (MAIN CENTER)	F	20	0.6100 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	06/21/2022	18.7	NG/L	2 NG/L	WELL #3: PUMP ROOM (ADULT CENTER)	F	20	0.5880 NG/L
GROTONWOOD BAPTIST CAMP AND CONF.CTR.	NC	PFAS	PFAS6	06/21/2022	ND	NG/L	2 NG/L	WELL #4: PUMP ROOM (FAMILY CENTER)	F	20	0.6150 NG/L
STILL MEADOW	COM	PFAS	PFAS6	10/22/2021	ND	NG/L	2 NG/L	WELL #1	F	20	0.6350 NG/L
STILL MEADOW	COM	PFAS	PFAS6	01/28/2022	ND	NG/L	2 NG/L	WELL #1	F	20	0.6230 NG/L
STILL MEADOW	COM	PFAS	PFAS6	04/22/2022	ND	NG/L	2 NG/L	WELL #1	F	20	0.6450 NG/L
STILL MEADOW	COM	PFAS	PFAS6	07/25/2022	ND	NG/L	2 NG/L	WELL #1	F	20	0.6660 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	09/10/2019	2.02	NG/L	1.8600 NG/L	TOWNSEND ROAD WTP - RAW WATER	R		Not Recorded

WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	10/04/2021	ND	NG/L	2 NG/L	FINISHED: TOWN FOREST WTP	F	20	0.6050 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	10/26/2021	2.85	NG/L	2 NG/L	FINISHED: TOWNSEND RD WTP	F	20	0.6170 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	01/12/2022	ND	NG/L	2 NG/L	FINISHED: TOWNSEND RD WTP	F	20	0.6180 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	01/12/2022	ND	NG/L	2 NG/L	FINISHED: TOWN FOREST WTP	F	20	0.6070 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	04/25/2022	ND	NG/L	2 NG/L	FINISHED: TOWN FOREST WTP	F	20	0.6180 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	04/25/2022	2.14	NG/L	2 NG/L	FINISHED: TOWNSEND RD WTP	F	20	0.6180 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	07/22/2022	2.38	NG/L	2 NG/L	FINISHED: TOWNSEND RD WTP	F	20	0.6120 NG/L
WEST GROTON WATER SUPPLY DISTRICT	COM	PFAS	PFAS6	07/22/2022	ND	NG/L	2 NG/L	FINISHED: TOWN FOREST WTP	F	20	0.6140 NG/L